

CPP ~

Wind Engineering Consultants

***Specifying Exhaust Systems to Minimize
Energy Cost While Maintaining Acceptable
Air Quality***

***Laboratories for the 21st Century
October 6-9, Raleigh/Durham, NC***

by

Ron Petersen, Ph.D.

and

John Carter


Cermak Peterka Petersen, Inc.

rpetersen@cppwind.com

OUTLINE

- ✍ **Reentry of Pollutants**
- ✍ **Specification of Acceptable Exhaust Design**
- ✍ **Relating Energy Cost to Exhaust Design**
- ✍ **Examples from Recent Projects**

Acceptable Air Quality & Reentry of Pollutants



*Specifying Exhaust and Intake
Systems
by
Petersen, Cochran and Carter
ASHRAE Journal, August 2002*

Plume impact on taller downwind building



Plume impacting taller upwind building



Specifying an Acceptable Design

Identify Exhaust Sources of Concern

Develop Design Criteria

Concentration (or Dilution) Predictions
(Numerical Modeling; Physical Modeling; Full Scale Testing)

Modify Design
or Criteria

Design
Acceptable
?

Yes


No

GOOD DESIGN

{

Identify Sources of Concern

Boiler



Radioisotope



Biosafety Cabinet & Isolation Room



Chemical Fume Hood

Cooling Tower



Animal Room



Traffic



Emergency Generator

Helicopter




Diesel Vehicles


Also:

- Kitchen Hood Exhaust
- Ethylene Oxide (EtO)


Concentration Design Criteria (continued)



Health Limits (C_{health})


 Lowest of ACGIH, OSHA and NIOSH

- STELs (15 Minute Averaging Time)
- 8 hr TWA multiplied by 3

 Safety Factor of 5
(ANSI/AIHA Z9.5 – Changing)

Odor Thresholds (C_{odor})

 ACGIH; various research



Concentration Design Criteria (continued)



✍ Mass emission rates (m)

✍ Chemical hood emissions

- EPA equation for accidental spill

$$m = 6.94 \times 10^{-4} (1 + 0.0043[T - 273.15]^2) U_r^{0.75} A M \frac{V_p}{V_{pk}}$$

- 1 minute lecture bottle evacuation

General Design Criteria

ASHRAE Lab Handbook Chapter 13

 Use 5000:1 for 1000 cfm flow

 Use 400 mg/m³ per g/s

ASHRAE 110 Fume Hood Testing

 Use 3000:1 for 1000 cfm flow

 Use 700 mg/m³ per g/s

 AM.05 Rating.


Concentration Predictions

- ✍ **Analytical – may add energy cost**
- ✍ **Computational Fluid Dynamics (CFD) – not ready for routine applications**
- ✍ **Wind Tunnel Modeling (WT) – most accurate, best for optimizing design**
- ✍ **See previous presentations @ www.epa.gov/labs21century**

Wind Tunnel Modeling -- Like a Field Study, Controlled Meteorology, Design Changes



Wind Tunnel Concentration Measurements at Air Intake





*Relating Energy Costs to
Exhaust Design*

Exhaust Design Factors Affecting Energy Costs

- ✍ **Air Intake Locations**
- ✍ **Building Design and Existing Environment**
- ✍ **Chemical Utilization**
- ✍ **Volume Flow/Exit Velocity**
- ✍ **Local Meteorology**

Exhaust Evaluation Approach

Air quality acceptability question:

LEEDS Credit 9.1 -- Meet all standards and generally accepted guidelines for outdoor protection of workers and general public from C_{max} airborne chemical, radioactive and biological hazards. Use mathematical modeling, physical modeling and/or post construction testing and certification to prove compliance.

Factors Affecting Concentration

$$C = \frac{m}{\{ \sigma_y \sigma_z U_s \}} \exp\left[-\frac{H^2}{2\sigma_z^2}\right] \times 10^6$$

$$\frac{1}{\{ \sigma_y \sigma_z U_s \}}$$

Site and Design Effects Term

$$m \exp\left[-\frac{H^2}{2\sigma_z^2}\right]$$

Energy Term

{

Plume Rise Predictions – Main Energy Term


$$H \sim h_s + A [CFM \times FPM]^{1/3}$$

~ Fan Horsepower

Entrained Air Stacks on Lab Roof



Conventional vs. Entrained Air – 20 mph



—■— Conventional (15,000 cfm) —◆— Entrained (25,000 cfm) —▲— Difference

Examples

 *CDC Building 110*

 *Pomona College*


 *Commercial Medical Research Lab*

Stack Design and Results Information

| Source Description | Stack ID | Stack Height hs (ft) | Volume Flow Rate Q (cfm) | Exit Velocity Ve (fpm) | Motor Size ¹ (bhp) | Annual Energy Cost (\$) | Design Criterion HL/m ($\mu\text{g}/\text{m}^3$)/(g/s) | Max Measured C/m ($\mu\text{g}/\text{m}^3$)/(g/s) |
|--|---------------|----------------------------|--------------------------------|------------------------------|----------------------------------|----------------------------|--|---|
| CDC Building 110 - Laboratory | | | | | | | | |
| Initial Specifications | CDC-Lab (EAE) | 21.0 | 60,000 | 3,056 | 52.3 | \$20,340 | 230 | 81 |
| Recommended Specifications | CDC-Lab (CE) | 21.0 | 30,000 | 1,528 | 25.9 | \$10,054 | 230 | 162 |
| CDC Building 110 - Emergency Room | | | | | | | | |
| Recommended Specifications (Conventional) | | 6.4 | 5,800 | 6,292 | | | | |
| Recommended Specifications (Axijet 1500) | CDC-ER (EAE) | 6.4 | 8,210 | 3,898 | 6.9 | \$2,683 | 230 | 236 |
| Equivalent Recommended Specifications (Conventional) | CDC-ER (CE) | 6.4 | 10,606 | 3,000 | 8.8 | \$3,404 | 230 | 259 |
| Pomona College NBB - Laboratory | | | | | | | | |
| Initial Specification (Axijet 3650) | PC-Lab (EAE) | 12.9 | 24,000 | 3,876 | 15.6 | \$6,083 | 400 | Not Tested |
| Recommended Specifications (Conventional) | PC-Lab (CE) | 10.0 | 15,000 | 3,000 | 12.6 | \$4,910 | 400 | 339 |
| Commercial Medical Research - Laboratory | | | | | | | | |
| Entrained Air Exhaust (Axijet 6000) | CMR-Lab (EAE) | 22.8 | 64,000 | 4,420 | 41.4 | \$16,093 | 230 | 230 |
| Conventional Exhaust | CMR-Lab (CE) | 30.0 | 40,000 | 3,000 | 34.7 | \$13,482 | 230 | 212 |
| Commercial Medical Research - Vivarium | | | | | | | | |
| Entrained Air Exhaust (Axijet 6600) | CMR-Viv (EAE) | 22.5 | 96,000 | 6,630 | 67.3 | \$26,158 | 353 | 92 |
| Conventional Exhaust | CMR-Viv (CE) | 17.5 | 60,000 | 3,000 | 52.3 | \$20,340 | 353 | 209 |
| Commercial Medical Research - Biosafety Cabinet | | | | | | | | |
| Entrained Air Exhaust (Axijet 1825) | CMR-BSC (EAE) | 25.0 | 9,200 | 4,819 | 4.2 | \$1,649 | 400 | 440 |
| Conventional Exhaust | CMR-BSC (CE) | 32.0 | 4,000 | 3,000 | 2.9 | \$1,139 | 400 | 400 |
| Commercial Medical Research - Radioisotope | | | | | | | | |
| Entrained Air Exhaust (Axijet 1825) | CMR-RIE (EAE) | 7.0 | 9,200 | 4,819 | 2.2 | \$863 | 4,637 | 2,892 |
| Conventional Exhaust | CMR-RIE (CE) | 17.0 | 2,000 | 3,000 | 1.2 | \$453 | 4,637 | 3,182 |

1) Motor size for conventional system based on 4 in static pressure.

Fan Power Requirements - Total Discharge Q




Inputs to Calculations

~~✎~~ $kW - hr = 0.7457 \times bhp - hr$

~~✎~~ $Unit\ cost = \$0.06\ per\ kW-hr$

CDC Building 110



CDC Building 110

Laboratory Exhaust Stacks

| Parameter | Entrained Air | Conventional |
|------------------------|---------------|--------------|
| Stack Height (ft) | 21 | 21 |
| Volume Flow (cfm) | 60,000 | 30,000 |
| Exit Velocity (fpm) | 3,056 | 1,528 |
| Fan Size (HP) | 52 | 26 |
| Annual Energy Cost | \$20,340 | \$10,054 |
| Design Criterion, HL/m | 230 | 230 |
| Max Measured C/m | 81 | 162 |

CDC Building 110

Emergency Room

| Parameter | Entrained Air | Conventional |
|------------------------|---------------|--------------|
| Stack Height (ft) | 6.4 | 6.4 |
| Volume Flow (cfm) | 8,210 | 10,606 |
| Exit Velocity (fpm) | 3,898 | 3,000 |
| Fan Size (HP) | 6.9 | 8.8 |
| Annual Energy Cost | \$2,683 | \$3,404 |
| Design Criterion, HL/m | 230 | 230 |
| Max Measured C/m | 236 | 259 |

CDC Building 110 – Lab Exhaust



Pomona Model



{

Pomona Research Lab



Pomona College

Laboratory Exhaust Stacks


| Parameter | Entrained Air | Conventional |
|------------------------|---------------|--------------|
| Stack Height (ft) | 12.9 | 10 |
| Volume Flow (cfm) | 24,000 | 15,000 |
| Exit Velocity (fpm) | 3,876 | 3,000 |
| Fan Size (HP) | 15.6 | 12.6 |
| Annual Energy Cost | \$6,083 | \$4,910 |
| Design Criterion, HL/m | 400 | 400 |
| Max Measured C/m | <339 | 339 |

Pomona Lab Exhaust



{

Medical Research Laboratory



{

Medical Research Laboratory

Laboratory

| Parameter | Entrained Air | Conventional |
|------------------------|---------------|--------------|
| Stack Height (ft) | 22.8 | 30 |
| Volume Flow (cfm) | 64,000 | 40,000 |
| Exit Velocity (fpm) | 4,420 | 3,000 |
| Fan Size (HP) | 41.4 | 34.7 |
| Annual Energy Cost | \$16,093 | \$13,482 |
| Design Criterion, HL/m | 230 | 230 |
| Max Measured C/m | 230 | 212 |

Medical Research Laboratory

Vivarium

| Parameter | Entrained Air | Conventional |
|------------------------|---------------|--------------|
| Stack Height (ft) | 22.5 | 17.5 |
| Volume Flow (cfm) | 96,000 | 60,000 |
| Exit Velocity (fpm) | 6,630 | 3,000 |
| Fan Size (HP) | 67.3 | 52.3 |
| Annual Energy Cost | \$26,158 | \$20,340 |
| Design Criterion, HL/m | 353 | 353 |
| Max Measured C/m | 92 | 209 |

Summary – Specifying Exhausts to Minimize Energy Use



- ✍ *Use guidelines*
- ✍ *Caution using vendor effective height specification – evaluate like regular exhaust*
- ✍ *Recommended approach*
 - ✍ *Design criteria development*
 - ✍ *Concentration predictions using accurate method*
 - ✍ *Design to meet criteria*
- ✍ *Designs that avoid air quality problems and minimize energy costs*